

REMOTE OPTIONS

Remote Key -----
 Disarm NO YES

SYSTEM REPORTS

Opening/Closing Reports NO YES
 Abort Reports NO YES
 Zone Restoral Reports NO YES DISARM
 Bypass Reports NO YES
 Code Change Reports NO YES
 Ambush Reports NO YES
 Late To Open Minutes -- (0 to 240 min.)
 Early To Close Minutes -- (0 to 240 min.)

SYSTEM OPTIONS

System AREA A/P H/S/A
 Closing Code NO YES
 Closing Check NO YES
 Entry Delay 1 -- (30 to 250 sec., default = 30)
 Entry Delay 2 -- (30 to 250 sec., default = 60)
 Exit Delay -- (45 to 250 sec., default = 60)
 Cross Zone Time -- (0, 4 to 250 sec.)
 Power Fail Delay -- (0, 1 to 9 hrs.)
 Swinger Bypass Trips -- (0 to 6, default = 2)
 Reset Swinger Bypass NO YES
 Zone Activity Hours -- (0 to 9 hrs.)
 Arm Activity Days -- (0 to 99 days)
 Time Change NO YES
 Hours from GMT -- (0 to 23 hrs., default = 6)
 Time Display NO YES
 House Code -- (1 to 50)
 Detect Wireless Jamming NO YES
 Wireless Audibles ANY DAY MIN
 Enable Keypad Panic Keys NO YES
 Occupied Premises NO YES
 Use False Alarm Question NO YES

BELL OPTIONS

Bell Cutoff Time -- (1 to 15 min., default = 5)
 Automatic Bell Test NO YES
 Bell Output -- (0, 31-34, 41-44, F1-20)

Bell Action . . .

Fire Zones	Steady	Pulse	Temporal	None
Burglary Zones	Steady	Pulse	Temporal	None
Supervisory Zones	Steady	Pulse	Temporal	None
Panic Zones	Steady	Pulse	Temporal	None
Emergency Zones	Steady	Pulse	Temporal	None
Auxiliary 1 Zones	Steady	Pulse	Temporal	None
Auxiliary 2 Zones	Steady	Pulse	Temporal	None

OUTPUT OPTIONS

Comm Fail Output -- (0, 31-34, 41-44, F1-20)
 Fire Alarm Output -- (0, 31-34, 41-44, F1-20)
 Panic Alarm Output -- (0, 31-34, 41-44, F1-20)
 Entry Output -- (0, 31-34, 41-44, F1-20)
 Begin Exit Output -- (0, 31-34, 41-44, F1-20)
 End Exit Output -- (0, 31-34, 41-44, F1-20)
 Ready Output -- (0, 31-34, 41-44, F1-20)
 Armed Output -- (0, 31-34, 41-44, F1-20)
 Disarmed Output -- (0, 31-34, 41-44, F1-20)
 Burglary Output -- (0, 31-34, 41-44, F1-20)
 Arm-Alarm Output -- (0, 31-34, 41-44, F1-20)
 Heat Saver Temperature -- (0, 55 to 95 degrees)
 Cool Saver Temperature -- (0, 55 to 95 degrees)

OUTPUT INFORMATION (WIRELESS)

Output No. *	Output Name	Serial Number	Supervision Time	Trip with Panel Bell (YES or NO)
31	OUTPUT 1			
32	OUTPUT 2			
33	OUTPUT 3			
34	OUTPUT 4			
41	ALARM SOUNDER 1			
42	ALARM SOUNDER 2			
43	ALARM SOUNDER 3			
44	ALARM/ALARM LIGHT			

Note: Assign Output Numbers 31 to 34 for slow response time wireless outputs (activates within 15 seconds) or 41 to 44 for fast response time wireless outputs (activates within 1 second). Assign an 1135 Wireless Siren to any output number and it operates with a fixed 3 second response.

AREA INFORMATION

Area #	Area Name	Auto Arming N or Y	Bad Zones BYP, FORC, or REF	Auto Disarm N or Y
1				
2				
3				
4				
5				
6				

ZONE INFORMATION

XTLN Zone Information		Key Fob	Type	Area	DMP Wireless				Disarmed Open		Disarmed Short		Armed Open		Armed Short		Entry Delay	Cross Zone	Priority	Traffic Count	Zone Audit Days	Receiver Routing	TGL Style										
Zone #	Zone Name	Serial Number	NT DY FI EM A1 A2 FV AR Y	INT BDRM PERIM or 1 to 6	Contact	External N/O?	114 Contact	Supervision Time	LED Operation	Disarm-Disable	PIR Pulse Count	Sensitivity	Message	Output *	Action	Message	Output *	Action	Message	Output *	Action	Swinger	Prewarn	Entry Delay	Cross Zone	Priority	Traffic Count	Zone Audit Days	Receiver Routing	TGL ARM DIS STEP MNT			
	NIGHT		N	NT	INT	N	1	240	Y	Y	4	Low	-	0	S	A	0	S	A	0	S	Y			N	N	0						
	DAY		N	DY	INT	N	1	240	Y	Y	4	Low	T	0	S	A	0	S	A	0	S	Y			N	N	0						
	EXIT		N	EX	INT	N	1	240	Y	Y	4	Low	-	0	S	A	0	S	A	0	S	Y	1-5		N	N	0						
	FIRE		N	FI	INT	N	1	240	Y	Y	4	Low																					
	PANIC		N	PN	INT	N	1	240	Y	Y	4	Low																					
	EMERGENCY		N	EM	INT	N	1	240	Y	Y	4	Low																					
	SUPERVISORY		N	SV	INT	N	1	240	Y	Y	4	Low																					
	AUXILIARY 1		N	A1	INT	N	1	240	Y	Y	4	Low																					
	AUXILIARY 2		N	A2	INT	N	1	240	Y	Y	4	Low	T	0	S	A	0	S	A	0	S	Y			N	N	0						
	FIRE VERIFY		N	FV	INT	N	1	240	Y	Y	4	Low	T	0	S	A	0	S	A	0	S	Y			N	N	0						
	ARMING		N	AR	INT	N	1	240	Y	Y	4	Low																					



800-641-4282

www.dmp.com

Designed, Engineered and
Assembled in U.S.A.

INTRUSION • FIRE • ACCESS • NETWORKS

2500 North Partnership Boulevard

Springfield, Missouri 65803-8877

LT-1222 © 2013 Digital Monitoring Products, Inc. 13455