

## Compliance Note

---

### Underwriters Laboratories Listings

#### [ALVY.S3598](#)

#### **Access Control System Units**

The basic standard used to investigate products in this category is UL 294, "Access Control System Units."

#### [AMCX.S3598](#)

#### **Central Station Alarm Units (Commercial Burglary)**

The basic standards used to investigate products in this category are UL 1610, "Central-Station Burglar Alarm Units" and UL 1635, "Digital Alarm Communicator System Units."

#### [UTOU.S3598](#)

#### **Control Units and Accessories, Household System Type (Residential Fire)**

The basic standard used to investigate products in this category is UL 985, "Household Fire-Warning System Units."

#### [UOJZ.S3598](#)

#### **Control Units, System (Commercial Fire)**

The basic standard used to investigate products in this category is UL 864, "Control Units for Fire-Protective Signaling Systems."

#### [UOXX.S3598](#)

#### **Control Unit Accessories, System (Commercial Fire - Accessories)**

The basic standard used to investigate products in this category is UL 864, "Control Units for Fire-protective Signaling Systems."

#### [NBSX.S3598](#)

#### **Household Burglar Alarm System Units (Residential Burglary)**

The basic standard used to investigate products in this category is UL 1023, "Household Burglar Alarm System Units."

#### [APOU.S5392](#)

#### **Proprietary Alarm Units (Commercial Burglary)**

The basic standard used to investigate products in this category is UL 1076, "Proprietary Burglar Alarm Units and Systems."

#### [ANET.S5392](#)

#### **Holdup Alarm Units**

The basic standard used to investigate products in this category is UL 636, "Holdup Alarm Units and Systems"

[AOTX.S3598](#) **Police Station Alarm Units (Commercial Burglary)**

The basic standards used to investigate products in this category are UL 365, "Police Station Connected Burglar Alarm Units and Systems" and UL 464, "Audible Signal Appliances."

[UROX.S7237](#) **Smoke-Automatic Fire Detectors**

The basic standard used to investigate open-area and releasing-service detectors in this category is ANSI/UL 268"Smoke Detectors for Fire Alarm Signaling Systems."

## Underwriters Laboratories of Canada Listings

[AMCXC.S3598](#) **Central and Monitoring Station Burglar Alarm System Units (Commercial Burglary)**

Products listed to this CCN/Guide No. have been found to meet the applicable requirements of the following: CAN/ULC-S304 "Standard for Central and Monitoring Station Burglar Alarm Units".

[NBSX7.S3598](#) **Household Burglar Alarm System Units**

Products listed to this CCN/Guide No. have been found to meet the applicable requirements of the following: ULC Subject-C1023," Household Burglar Alarm System Units".

[UTOUC.S3598](#) **Household Fire Warning System Units (Residential Fire)**

Products listed to this CCN/Guide No. have been found to meet the applicable requirements of ULC-S545, "Standard for Residential Fire Warning System Control Units".

[APOU7.S3598](#) **Proprietary Burglar Alarm System Units (Commercial Burglary)**

Products listed to this CCN/Guide No. have been found to meet the applicable requirements of the following: ULC/ORD-C1076, "Standard for Proprietary Burglar Alarm Units and Systems "

[DAYR7.S3598](#) **Central Station Fire Alarm System Units (Fire Communicator)**

The basic standard used to investigate products in this category is CAN/ULC-S559, "Equipment for Fire Signal Receiving Centers and Systems."

## NIST Certification

[AES 2350](#) XR550E Encryption Certificate - 128-bit

[AES 2595](#) XR550E Encryption Certificate - 256-bit

## California State Fire Marshal Listing

[135](#) Control Unit (Commercial) XR150, XR350, XR550

[134](#) Control Unit (Household) XR150, XR350, XR550

[137](#) 2W-BLX/2WT-BLX Smoke Detectors

[112](#) Pull Stations (850S/850D)

## New York City Fire Department

[FDNY COA](#) Fire Alarm Equipment - XR150D, XR150DN, XR150DFC, XR150DNFC, XR550D, XR550DN, XR550DFC, XR550DNFC, XR550DE

## Los Angeles Fire Department

[Approval Letter](#) 263LTE-V